

TAG Meeting April 16, 2013

NCEMC Office Raleigh, NC



TAG Meeting Agenda

- 1. Administrative Items Rich Wodyka
- 2. FERC Order No. 1000 Rule on Transmission Planning Sam Waters
- 3. 2013 Study Activities and Study Scope Update Mark Byrd
- 4. 2012 NCTPC PJM Joint Interregional Reliability Study Report Orvane Piper
- 5. Regional Studies Update Bob Pierce
- 6. 2013 TAG Work Plan Rich Wodyka
- 7. TAG Open Forum Rich Wodyka



FERC Order No. 1000 Rule on Transmission Planning and Cost Allocation Compliance Update

Sam Waters – Duke Energy

on behalf of the North Carolina Transmission Planning Collaborative



Regional Compliance Update

- ➤ Duke Energy Carolinas and Progress Energy Carolinas submitted the Order No. 1000 regional compliance filing on October 11, 2012.
- ➤ FERC issued an order on February 21, 2013 finding that due to the merger of Duke and Progress, Duke and Progress are no longer separate transmission providers for purposes of Order No. 1000 compliance and therefore the NCTPC no longer qualified as an Order No. 1000 transmission planning region.



Regional Compliance Update (cont.)

- Duke-Progress submitted a request for rehearing/ clarification of the FERC order.
 - Rehearing request Requested that FERC reconsider their finding and find that Duke and Progress are separate transmission providers.
 - Clarification request If FERC does not find that Duke and Progress are separate transmission providers then FERC should clarify that Duke and Progress have a single footprint for Order No. 1000 purposes.



Regional Compliance Update (cont.)

- Rehearing/Clarification request responded to LS Power's request for clarification of the FERC order requesting FERC determine that a Duke-Progress transmission project would be a regional project, instead of a local project.
- > NCEMC submitted an Answer to the LS Power filing:
 - Requested that FERC reject the LS Power request for clarification. A Duke-Progress project should be considered a local project.
 - If FERC rejects the Duke-Progress request for rehearing of the order, NCEMC stated that the NCTPC process should continue to be used for local transmission planning.



Regional Compliance Update (cont.)

- ➤ Based on the FERC order, Duke is working to join the SERTP region.
- Duke's revised regional compliance proposal will include the following:
 - Preservation of the NCTPC as a local transmission planning process
 - Use of the SERTP as the regional transmission planning process
- Schedule for revised regional compliance filing
 - April 23: Release draft Tariff for stakeholder review/comment
 - May 7: Stakeholders provide comments on the draft
 - May 22: Duke-Progress submit filing



Interregional Compliance Update

- SERTP Sponsors will be submitting their interregional compliance filings
- Stakeholder input to the SERTP interregional strawman should be provided to the SERTP
- ➤ Following slides are from the SERTP April 10th meeting where the interregional strawman was discussed



SERTP Interim Meeting

October 17th
FERC Order 1000 Discussion



"SERTP"

Background

Background


- The Southeastern Regional Transmission Planning ("SERTP") Process was formed in 2007 by:
 - Dalton Utilities ("Dalton")
 - Georgia Transmission Corporation ("GTC")
 - Municipal Electric Authority of Georgia ("MEAG")
 - PowerSouth Electric Cooperative ("PowerSouth")
 - South Mississippi Electric Power Association ("SMEPA")
 - Southern Companies ("Southern")

Background

- Recently, the SERTP has received an extension of time to submit an Order 1000 compliance filing that expands the SERTP region to include the following entities:
 - Associated Electric Cooperative, Inc. ("AECI")
 - Louisville Gas & Electric and Kentucky Utilities ("LGE / KU")
 - Ohio Valley Electric Corporation ("OVEC")
 - Tennessee Valley Authority ("TVA")

Motion for Extension

• FERC granted the 120 day extension on September 6th, 2012 extending the filing due date until February 8, 2013



- Original SERTP
 - Southern
 - GTC
 - MEAG
 - Dalton
 - PowerSouth
 - SMEPA
- TVA
- AECI
- LG&E / KU
- OVEC



- Associated Electric Cooperative, Inc.
 - ❖AECI is owned by and provides wholesale electricity to six G&Ts who serve 51 Distribution Cooperatives with a combined service area covering 90,414 square miles.
 - Headquarters: Springfield, MO
 - Miles of Transmission Line ≈ 9,650
 - Historical Peak Demand ≈ 4,495
 - Number of Member Consumers ≈ 875,000
 - States
 - Missouri
 - Northeast Oklahoma
 - Southeast Iowa

Dalton Utilities

- Established in 1889, DU provides electric, natural gas, water, wastewater, stormwater & telecommunications services to approximately 77,000 customers in Dalton, GA and five surrounding counties.
 - Headquarters: Dalton, GA
 - Miles of Transmission Line ≈ 305
 - Historical Peak Demand ≈ 272 MW
 - Number of Electric Consumers ≈ 18,200
 - States
 - Georgia




- Georgia Transmission Corporation
- GTC is an electric membership corporation that provides transmission service to 39 retail distribution cooperative members in the state of Georgia.
 - Headquarters: Tucker, GA
 - Formed in 1997 with restructuring of Oglethorpe Power Corporation
 - Miles of Transmission Line ≈ 3,100
 - Historical Peak Demand ≈ 9,300 MW
 - Members serve approximately 4 million people



LG&E / KU

- Louisville Gas & Electric and Kentucky Utilities are vertically integrated companies that serve two-thirds of the counties in Kentucky and parts of Virginia.
 - Headquarters
 - Louisville, Kentucky
 - Miles of Transmission Line
 ~5000
 - Historical Peak Demand
 7,175 MW
 - Number of Customers
 - o 943,000 (Electricity)
 - 321,000 (Natural Gas)
 - States
 - Kentucky
 - Virginia



MEAG Power

- ❖A public corporation and an instrumentality of the State of Georgia providing G&T service to 48 cities and one county.
 - Headquarters: Atlanta, GA
 - Miles of Transmission Line ≈ 1320
 - Historical Peak Demand ≈ 2200 MW
 - Number of City and County Consumers ≈ 310,000
 - States
 - Georgia

OVEC

- OVEC, and its wholly owned subsidiary Indiana-Kentucky Electric Corporation (IKEC), owns and operates a 345kV transmission system across three states; Ohio, Kentucky, and Indiana.
 - Headquarters: Piketon, OH
 - Miles of Transmission Line ≈ 660
 - Peak Generation ≈ 2,200 MW
 - Sell Only to Sponsoring Utilities
 - By contract, owners are entitled to all generation
 - DOE facility in Balancing Area; Supplied by off-system sources

PowerSouth

- ❖ PowerSouth is a G&T Cooperative consisting of 16 Distribution Cooperatives and 4 Municipal systems with a total service area of approximately 31,000 square miles.
 - Headquarters: Andalusia, Alabama
 - Miles of Transmission Line ≈ 2,240
 - Historical Peak ≈ 2,400 MW
 - Number of Customers ≈ 418,000
 - States
 - Alabama
 - Florida



Southern Company


- Southern Company, which includes four retail operating companies, provides electric service across 120,000 square miles in four states.
 - Headquarters: Atlanta, GA
 - Miles of Transmission Line ≈ 27,000
 - Historical Peak Demand ≈ 38,500 MW
 - Number of Customers ≈ 4,400,000
 - States
 - Alabama (Alabama Power Company)
 - Georgia (Georgia Power Company)
 - Mississippi (Mississippi Power Company)
 - Florida (Gulf Power Company)

SMEPA

- South Mississippi Electric Power Association is a rural electric cooperative that generates, transmits and sells power to 11 member distribution cooperatives in Mississippi.
 - Headquarters: Hattiesburg, MS
 - Miles of Transmission Line ≈ 1,741
 - Historical Peak Demand ≈ 1507 MW
 - Number of Customers ≈ 410,000 homes/businesses
 - States
 - Mississippi



- Tennessee Valley Authority (TVA)
- Corporation owned by the U.S. government, provides electricity for 9 million people across 80,000 square miles in parts of seven southeastern states.
 - Headquarters
 - Knoxville, Tennessee
 - Miles of Transmission Line
 - o ~16,000 (2,500 500kV)
 - Historical Peak Demand
 - o 33,482 MW
 - Number of Customers
 - 155 distributors
 - 58 direct served customers
 - States
 - Alabama
- North Carolina
- Georgia
- Tennessee
- Kentucky
- Virginia
- Mississippi





FERC Order 1000

Stakeholder Discussion October 17th, 2012



FERC Order 1000

High-Level Overview

- Order 890
 - Transmission Planning Principles
 - Coordination
 - Openness
 - Transparency
 - Information Exchange
 - Comparability
 - Dispute Resolution
 - Regional Participation
 - Economic Planning Studies
 - Cost Allocation



- Planning Requirements
 - Produce a regional transmission plan, consistent with the principles of Order 890
 - Develop procedures to identify those transmission needs driven by public policy requirements for which potential transmission solutions will be evaluated
 - Determine merchant developer information/data necessary to assess impacts of proposed facilities



- Cost Allocation Requirements
 - Develop a method for allocating costs of those facilities that have been selected in the regional plan for purposes of cost allocation
 - Regional Cost Allocation Methodology
 - Interregional Cost Allocation Methodology
 - Regional and interregional cost allocation methodologies must satisfy the six cost allocation principles

Order 1000

Six Cost Allocation Principles

- The cost of transmission facilities allocated in a way that is roughly commensurate with benefits.
- 2) No involuntary allocation of costs to those who receive no benefits.
- 3) Benefit to Cost threshold, if used to determine if facilities have sufficient net benefits to be selected for regional cost allocation, cannot exceed 1.25.
- 4) The cost allocation method cannot allocate costs to entity's outside the region, unless that entity voluntarily agrees to assume cost.
- 5) The cost allocation method and data requirements for determining benefits and identifying beneficiaries must be transparent.
- 6) A region may have different cost allocation methods for different types of facilities. Each cost allocation method must be clearly set out and explained.



FERC Order 1000

SERTP October 17th Proposal



- Regional Requirements Order 1000
 - Develop procedures to identify those transmission needs driven by public policy requirements, for which potential transmission solutions will be evaluated

- Consideration of Transmission Needs Driven by Public Policy Requirements (PPRs)
 - SERTP Sponsors address transmission needs driven by PPRs in the routine planning, design, construction, operation, and maintenance of the transmission system.
 - Sponsors consider input of SERTP Stakeholders regarding transmission needs driven by PPRs
 - To be considered in the upcoming transmission planning cycle, input should be provided no later than 60 days after the SERTP Annual Transmission Planning Summit.
 - PPR must be a federal or state law/regulation
 - Sponsors will provide and post a response to Stakeholder input



- Consideration of Transmission Needs Driven by Public Policy Requirements (PPRs)
 - The Sponsors will evaluate SERTP Stakeholder input to determine if there is a transmission need driven by the PPR identified by the Stakeholder
 - If a transmission need is identified, that is not already addressed in the expansion planning process, the SERTP Sponsors will identify a transmission solution to address the need in the expansion planning processes.
 - Stakeholder input regarding potential transmission needs driven by PPRs may be directed to the governing OATT process as appropriate.
 - Ex: if the potential transmission need identified by the SERTP Stakeholder is essentially a request by a network customer to integrate a new network resource, the request would be directed to that existing OATT process.

- Regional Requirements Order 1000
 - Determine which information/data is necessary for merchant developers to provide transmission providers in order to allow transmission providers to assess the reliability and operational impacts of proposed facilities

- Merchant Developer Data/Information
 - Merchant transmission developers who propose to develop a transmission facility potentially impacting the SERTP will provide information and data necessary for the Sponsors to assess potential reliability and operational impacts of the merchant transmission developer's proposed transmission facilities on the region, including:
 - Transmission project timing, scope, network terminations, steady-state and stability modeling data, HVDC data (as applicable), details of service commitments, and other data necessary to assess potential impacts.

- Regional Requirements Order 1000 A
 - A clear enrollment process will be established that defines how public utility and non-public utility transmission providers, make the choice to become part of, or to terminate participation in the SERTP region.



- Purpose
 - Entities that enroll in the SERTP may be allocated costs based upon the benefits received from a regional project included in the regional plan for Cost Allocation Purposes ("CAP")



- General Eligibility for Enrollment
 - A public utility or non-public utility, transmission service provider, and/or transmission owner having a statutory or tariff obligation to ensure that adequate transmission facilities exist to meet its firm service commitments within the SERTP region.



- Enrollment Requirement
 - A potential transmission developer and/or transmission dependent utility must enroll in the SERTP in order to be eligible to propose a regional project for CAP <u>if</u> it, an affiliate, or parent company has load in the region.



- How to Enroll?
 - A form will be posted on the Regional Planning website.
- How to withdraw from enrollment?
 - Provide written notification of such intent at least 60 days prior to the Annual Transmission Planning Summit.
 - Termination effective at the end of the then-current transmission planning cycle.
 - Enrollee remains subject to regional cost allocations made while enrolled.



- Regional Requirements Order 1000
 - Develop a method for allocating costs of those facilities that have been selected in the regional plan for purposes of cost allocation

- Transmission Developer Qualification Criteria
 - Demonstrate the necessary financial capability and technical expertise to develop, construct, operate and maintain the proposed transmission facility.
 - S&P credit rating of BBB- or higher (or similar credit rating from another agency if not rated by S&P)
 - AND demonstrated capability to finance U.S. energy projects equal to or greater than the cost of the proposed regional transmission project



- Transmission Developer Qualification Criteria
 - Demonstrate the necessary financial capability and technical expertise to develop, construct, operate and maintain the proposed transmission facility.
 - Demonstrated capability to develop, construct, operate, and maintain U.S. electric transmission projects of similar or larger complexity, size, and scope as the proposed project.
 - Summary of transmission projects in-service, under construction, and/or projects not completed including locations, operating voltages, mileages, development schedules, approximate installed costs; and how these facilities are owned, operated and maintained. This may include projects and experience provided by a parent company or affiliates or other experience relevant to the development of the proposed project.
 - List of NERC and/or Regional Entity reliability standard violations



- Transmission Facility Qualification Criteria
 - Regional in nature
 - Operating voltage of 300 kV or above
 - Spans 100 miles or more
 - Located in two or more balancing authorities
 - Consideration will be given to projects that do not fully meet the foregoing on a project by project basis to ensure the proposal satisfies similar regional criteria/provides similar regional benefits
 - Green-field project
 - Materially different from those projects previously considered in the expansion planning process
 - Able to be constructed and tied into the network by the recommended in-service date


- Submittal Regional Proposal for CAP
 - Demonstration of Qualification Criteria
 - Transmission Developer ("TD")
 - Regional Transmission Facility
 - NERC and/or Other Industry Registrations
 - Project Description
 - Capital Cost Estimate
 - Technical Analysis performed by "TD"
 - Data/Files to Evaluate the Proposal
 - Planned Approach to Satisfy Regulatory Req's
 - Submittal Fee
 - Deadline for Submittal



- Submittal Regional Proposal for CAP
 - Submittal Fee
 - A non-refundable, administrative fee of \$25,000 per regional proposal for CAP will be required
 - The fee will be used to offset the costs to review and process the qualification criteria and supporting documentation for each submittal

- Submittal Regional Proposal for CAP
 - Deadline for Submittal
 - To be considered in the upcoming transmission planning cycle, a regional proposal for CAP should be provided no later than 60 days after the SERTP Annual Transmission Planning Summit.
 - The transmission developer will be notified within 30 days after the submittal deadline if there is an incomplete submittal or if qualification criteria is not met.
 - Within 15 days of such notification, the transmission developer can resubmit the necessary supporting documentation to remedy identified deficiencies.





regional plan for CAP based upon subsequent reevaluation, project delays/abandonment, or failure to meet developmental milestones




- Evaluation of Proposals for Selection in a Regional Plan for CAP
 - Regional Benefit to Cost Ratio of at least 1.25:
 - Benefit: Transmission costs avoided by the displaced projects
 - <u>Cost:</u> Transmission cost of the regional project proposed for selection in a regional transmission plan for CAP plus any additional projects required to implement the proposal
 - Initial evaluation based upon planning level cost estimates. Subsequent evaluation(s) performed based upon detailed financial terms provided by the transmission developer.
 - To be selected for CAP, the proposal must be approved by the jurisdictional/governance authorities of the beneficiaries.



- Selection in a Regional Plan for CAP
 - If a regional transmission project is selected in a regional plan for CAP, the beneficiaries will be allocated costs of the regional transmission facility in proportion to their displaced transmission costs.



Cost Allocation Example



- Maintaining "Selected for CAP" Status
 - In order to remain included in a regional plan for CAP:
 - The regional proposal will continue to be evaluated in subsequent expansion planning process that reflect ongoing changes in actual and forecast conditions to ensure:
 - The regional proposal is still needed
 - The regional proposal remains more efficient & cost effective
 - The transmission developer must meet all established milestones necessary to develop and construct the transmission project, including:
 - Obtaining all necessary ROWs and environmental, state, and other governmental approvals
 - Executing a contract to address the terms and conditions associated with the development of the regional transmission project

Contract Terms & Conditions

- A contractual agreement(s) will address terms and conditions associated with the development of the regional transmission project in a regional plan for CAP, such as:
 - Specific financial terms associated with the development of the regional transmission project,
 - The allocation of the costs of the aforementioned facility,
 - Creditworthiness/project security requirements,
 - · Operational control of the regional transmission facility,
 - Milestone reporting, including schedule of projected expenditures,
 - Engineering, procurement, construction, maintenance, and operation of the regional transmission facility,
 - Emergency restoration and repair responsibilities,
 - Reevaluation of the regional transmission facility, and
 - Non-performance or abandonment

- Delay / Abandonment
 - SERTP Sponsors will determine if alternative transmission projects may be required in addition to, or in place of, the proposal due to a delay or abandonment in the development of the regional transmission project selected for CAP. Circumstances prompting this evaluation include:
 - If notification is provided by the transmission developer that the proposed facility will be delayed
 - If the Sponsors are otherwise informed or become aware that the transmission developer is not meeting established project milestones.







NCTPC 2013 Study Activities and Study Scope

Mark Byrd Progress Energy Carolinas



Purpose of Study

Assess Duke and Progress transmission systems' reliability and develop a single Collaborative Transmission Plan



Steps and Status of the Study Process

- 1. Assumptions Selected
- 2. Study Criteria Established
- 3. Study Methodologies Selected
- 4. Models and Cases Developed
- 5. Technical Analysis Performed
- 6. Problems Identified and Solutions Developed
- 7. Collaborative Plan Projects Selected
- 8. Study Report Prepared



Study Assumptions Selected

- > Study Years for reliability analyses:
 - Near-term: 2018 Summer, 2018/2019 Winter
 - Longer-term: 2023 Summer
- > LSEs provided:
 - Input for load forecasts and resource supply assumptions
 - Dispatch order for their resources
- Interchange coordinated between Participants and neighboring systems



Study Criteria Established

- NERC Reliability Standards
 - Current standards for base study screening
 - Current SERC Requirements
- > Individual company criteria



Study Methodologies Selected

- Thermal Power Flow Analysis
- Each system (Duke and Progress) will be tested for impact of other system's contingencies



Base Case Models Developed

- Started with 2012 series MMWG cases
- Detailed models for Duke and Progress systems
- Adjustments were made based on additional coordination with neighboring transmission systems
- Planned transmission additions from updated 2012 Plan were included in models



Resource Supply Options Selected

- > Last year
 - Hypothetical new base load generation
 - NCTPC-PJM inter-regional wind study
- > This year
 - Hypothetical import/export scenarios
 - Coordination with PJM for modeling transfers



North Carolina Transmission Planning Collaborative

2023 Hypothetical Import / Export

Resource From	Sink	Test Level (MW)
NORTH – PJM	Duke	1,000
SOUTH - SOCO	Duke	1,000
SOUTH - SCEG	Duke	1,000
SOUTH - SCPSA	Duke	1,000
EAST – Progress (CPLE)	Duke	1,000
WEST – TVA	Duke	1,000



North Carolina Transmission Planning Collaborative

2023 Hypothetical Import / Export

Resource From	Sink	Test Level (MW)
NORTH – PJM	Progress (CPLE)	1,000
SOUTH - SCEG	Progress (CPLE)	1,000
SOUTH – SCPSA	Progress (CPLE)	1,000
WEST – Duke	Progress (CPLE)	1,000
WEST – Duke	SOCO	1,000



North Carolina Transmission Planning Collaborative

2023 Hypothetical Import / Export

Resource From	Sink	Test Level (MW)
NORTH – PJM	Duke / Progress (CPLE)	1,000 / 1,000
WEST – Duke / Progress (CPLE)	PJM	1,000 / 1,000
EAST – Progress (CPLE)	PJM	1,000
WEST – Duke	PJM	1,000
SOUTH – SOCO *	PJM	1,000



Enhanced Transmission Access Requests

- TAG memo was distributed on February 1, 2013 requesting input
- ➤ The deadline for input was February 12, 2013
- The NCTPC is considering a joint wind study with South Carolina



Proposed Carolinas Joint Wind Study

- Joint effort of NCTPC and SCRTP
- Assess impacts of various wind injection sites along the NC and SC coasts
- Sites to be tested will be selected based on latest available off-shore wind data and studies



Technical Analysis

- Conduct thermal screenings of the 2018 and 2023 base cases
- Conduct thermal screenings of the 2023 hypothetical transfer scenarios and coordinate with PJM



Problems Identified and Solutions Developed

- Identify limitations and develop potential alternative solutions for further testing and evaluation
- Estimate project costs and schedule



Collaborative Plan Projects Selected

Compare all alternatives and select preferred solutions

Study Report Prepared

Prepare draft report and distribute to TAG for review and comment







NCTPC – PJM Joint Interregional Reliability Study Report


Orvane Piper Duke Energy



Scope of 2012 Joint Wind Study

- Year 2027 summer cases used for the Wind Generation Scenarios located off the North Carolina / Virginia coast
- Three off-shore injection points studied
 - Dominion's Landstown 230 kV Substation
 - PEC's Morehead City area
 - PEC's Southport area
- ➤ The load level of each study area was set to 60% of 2027 summer forecasted peak levels








Wind Study Methodology

- The 2027 off-peak case was screened for base thermal overloads and voltage violations
- The PEC system included transmission upgrades from prior NCTPC wind studies already incorporated
- A thermal N-1 analysis was conducted to test the postcontingency reliability of the network
- Solutions were determined, modeled in the scenario case, and then verified to ensure the solutions were effective








Scenario #1 PEC Upgrades Line/Equipment Name	Estimated Cost (M)	
Morehead 500 kV Switching Station		\$30
Jacksonville 500 kV Substation		\$60
Jacksonville - Morehead Switching Station 500 kV Lines		\$200
Wommack 500 kV Substation		\$60
Jacksonville - Wommack 500 kV Line		\$120
Southport 500 kV Switching Station		\$30
Sutton North 500 kV Substation (including 230 kV work)		\$70
Southport - Sutton North 500 kV Lines		\$150
Cumberland - Sutton North 500 kV Line		\$210
Cumberland 500 kV Substation - Add terminals		\$2
	TOTAL	\$932 M







Scenario #2 DEC Upgrades Line/Equipment Name	Estimated Cost (M)
McGuire – Riverbend 230 kV Line Reactors	\$4
TOTAL	\$4 M




Scenario #2 PEC Upgrades	Estimated Cost
Line/Equipment Name	(M)
Morehead 500 kV Switching Station	\$30
Jacksonville 500 kV Substation	\$30
Jacksonville - Morehead Switching Station 500 kV Lines	\$200
Wommack 500 kV Substation	\$30
Jacksonville - Wommack 500 kV Line	\$120
Cumberland - Jacksonville 500 kV Line	\$210
Jacksonville - Sutton North 230 kV Line	\$90
Southport 500 kV Switching Station	\$30
Sutton North 500 kV Substation (including 230 kV work)	\$70
Southport - Sutton North 500 kV Lines	\$150
Cumberland - Sutton North 500 kV Line	\$210
Cumberland 500 kV Substation - Add terminals	\$4
SVC at Sutton North	\$40
TOTAL	\$1,214 M



Scenario #2 PJM Upgrades Line/Equipment Name	Estimated Cost (M)
2nd Landstown – Stumpy Lake 230 kV Line	\$4
TOTAL	\$4 M







Scenario #3 DEC Upgrades Line/Equipment Name	Estimated Cost (M)
McGuire – Riverbend 230 kV Line Reactors	\$4
TOTAL	\$4 M



Scenario #3 PEC Upgrades Line/Equipment Name	Estimated Cost (M)
Morehead 500 kV Switching Station	\$30
Jacksonville 500 kV Substation	\$60
Jacksonville - Morehead Switching Station 500 kV Lines	\$300
Wommack 500 kV Substation	\$60
Jacksonville - Wommack 500 kV Lines	\$200
Cumberland - Jacksonville 500 kV Line	\$210
Jacksonville - Sutton North 500 kV Line	\$135
Wake - Wommack 500 kV Line	\$195
Wake 500 kV Sub - Add terminals	\$2
Southport 500 kV Switching Station	\$30
Sutton North 500 kV Substation (including 230 kV work)	\$70
Southport - Sutton North 500 kV Lines	\$150
Cumberland - Sutton North 500 kV Line	\$210
Cumberland 500 kV Substation- Add terminals	\$4
SVC at Sutton North	\$40
SVC at Wommack	\$40
TOTAL	\$1,736 M



Scenario #3 PJM Upgrades Line/Equipment Name	Estimated Cost (M)	
Landstown 500 kV Substation	\$18.5	
Landstown 500/230 kV Transformers	\$32	
Chickahominy 500/230 kV Transformer	\$16	
Surry – Chickahominy 500 kV Line	\$171	
Landstown – Fentress 500 kV Line	\$57	
Landstown – Yadkin 500 kV Line	\$38	
2 nd Landstown – Stumpy Lake 230 kV Line	\$4	
2 nd Stumpy Lake – Thrasher 230 kV Line	\$4	
2 nd Fentress – Thrasher 230 kV Line	\$8	
TOTAL	\$349 M	








Regional Studies Reports

Bob Pierce Duke Energy



South Carolina Regional Transmission Planning (SCRTP)

Existing Generation





Generation Plan Reductions

- 90 MW Coal 2013
- . 245 MW Coal 2017
- . 345 MW Coal 2018



Generation Plan


Additions

- 1117 MW of SCE&G/Santee Cooper Base Load Nuclear Generation planned for 2017 (V. C. Summer)
- 1117 MW of SCE&G/Santee Cooper Base Load Nuclear Generation planned for 2018 (V. C. Summer)





Generation Changes





Generation Resources

Existing Connected Generation

Cross 1-4

Grainger 1, 2

Hilton Head Turbines 1-3

Jefferies 1, 2, 3, 4, 6 (Hydro)

Jefferies 1, 2, 3, 4 (Steam)

Myrtle Beach Turbines 1-5

Winyah 1-4

J.S. Rainey Power Block 1

J.S. Rainey 2A, 2B

J.S. Rainey 3-5

Spillway (Hydro)

St. Stephen 1-3 (Hydro)

V.C. Summer #1



2013 Economic Planning Scenarios

Source	Sink	Amount (MW)	Year	Study Conditions
Southern	SCPSA	500	2014	Summer Peak
Southern	SCPSA	500	2014	Winter Peak



www.scrtp.com




PJM Baseline Reliability Assessment



- ➤ For the 2012 RTEP cycle, over 11,000 MW of existing generation has announced its intentions to deactivate in the near future.
- In order to establish a model which accurately included all expected generation retirements, PJM performed many sets of analysis to study the effects of these generation retirements on the system








American Transmission Systems, Incorporated

- ➤ Convert Eastlake unit 1 to synchronous condensers 6/1/2015 \$20M
- ➤ Convert Eastlake unit 2 to synchronous condensers 6/1/2015 \$20M
- ➤ Convert Eastlake unit 3 to synchronous condensers 6/1/2015 \$20M
- ➤ Convert Eastlake unit 4 to synchronous condensers 6/1/2014 \$20M
- Convert Eastlake unit 5 to synchronous condensers 6/1/2013 \$20M
- ➤ Convert Lakeshore 18 to a synchronous condenser 6/1/2015 \$20M









- Overview of Reliability Problem
 - Criteria Violation: Failure of ComEd dynamic voltage recovery criteria
 - Contingency:
 - Criteria test: ComEd criteria
- Overview of Reliability Solution
 - Description of Upgrade: Install two 300 MVAR SVC's on the 138
 kV red and blue buses at Prospect Heights substation
 - Upgrade In-Service Date: June 01, 2014
 - Estimated Upgrade Cost: \$75.00 M
 - Construction Responsibility: ComEd











- Overview of Reliability Problem
 - Criteria Violation: Voltage collapse in the VA Beach area
 - Contingency: Loss of Suffolk Yadkin 500 kV and Yadkin –
 Fentress 500 kV
 - Criteria test: NERC TPL-003 Category C (N-1-1 Voltage)
- Overview of Reliability Solution
 - Description of Upgrade: Install a 500 MVAR SVC at Landstown 230 kV
 - Upgrade In-Service Date: June 01, 2016
 - Estimated Upgrade Cost: \$60.00 M
 - Construction Responsibility: Dominion



- Overview of Reliability Problem
 - Criteria Violation: High voltage on the 230 kV transmission system in Northern Virginia during periods of light system load
 - Contingency:
 - Criteria test: Operation Performance, Light Load
- Overview of Reliability Solution
 - Description of Upgrade: Install four additional 230 kV 100 MVAR variable shunt reactor banks at Clifton, Gallows Road, Garrisonville, and Virginia Hills substations
 - Upgrade In-Service Date: December 01, 2013
 - Estimated Upgrade Cost: \$ 24.00 M
 - Construction Responsibility: Dominion



- Overview of Reliability Problem
 - Criteria Violation: High voltage on the 230 kV transmission system in Eastern Virginia during periods of light system load
 - Contingency:
 - Criteria test: Operation Performance, Light Load
- Overview of Reliability Solution
 - Description of Upgrade: Install two additional 230 kV 100 MVAR variable shunt reactor banks at Churchland and Shawboro substations
 - Upgrade In-Service Date: May 01, 2014
 - Estimated Upgrade Cost: \$ 12.00 M
 - Construction Responsibility: Dominion



Eastern Interconnection Planning Collaborative (EIPC)



EIPC background

> EIPC Objectives

- 1. Integration ("roll-up") and analysis of approved regional plans
- 2. Development of possible interregional expansion scenarios to be studied
- 3. Development of interregional transmission expansion options



EIPC Structure

Eastern Interconnection Planning Collaborative (EIPC)
(Open Collaborative Process)

EIPC Analysis Team Principal Investigators Planning Authorities

Steering Committee

Stakeholder Work Groups

Executive Leadership


Technical Leadership & Support Group Stakeholder Groups

States Provinces

es Federal


Owners Operators Users





- Stakeholder Specified Infrastructure part of the base model
- Scenario 1 Combined Policies (80% carbon reduction, significant EE/DR/DG), required largest transmission build out
 - This included significant HVDC needed to move power long distances





- Scenario 2, National RPS (30%) Implemented Regionally, required a fair amount of transmission
- Scenario 3, Business as Usual, required the least additional transmission



2030 O&M Costs - (\$2010 Billions)											
Costs	Co	Scenario 1: Combined Policy		Scenario 2: RPS Implemented Regionally		Scenario 3: Business as Usual					
Production Costs - Fuel	\$	40.8	\$	73.8	\$	85.1					
Production Costs - Variable O&M	\$	6.4	\$	15.5	\$	18.4					
CO2 Costs	\$	45.3	\$	0.1	\$	0.2					
Policy Driven Energy Efficiency	\$	8.9	\$	1.5	\$	1.5					
CO2 Price Driven Energy Efficiency	\$	10.0	\$	-	\$	-					
Demand Response O&M	\$	0.6	\$	0.3	\$	0.3					
Variable Resource Integration	\$	2.9	\$	2.5	\$	1.0					
Fixed O&M	\$	34.7	\$	52.1	\$	48.1					
Total O&M Costs	\$	149.6	\$	145.9	\$	154.5					
Total O&M Costs without CO2	\$	104.3	\$	145.7	\$	154.4					

- These costs are extremely high level, indicative only costs
 - Mix of annual 2030 costs and overnight capital costs
- Many costs have not been included in this analysis
- Costs reflect very different economies

	, ,		т .		_ +			Scenario 1	Scenario 2 Base -	Scenario 3
Overnight Capital Costs for Capital through 2030 (\$2010 Billions)							Base -	National RPS	Base -	
Costs	Sc	enario 1	Sc	enario 2	Scenario 3			Combined	Implemented	Business as
Transmission - Generation								Policies	Regionally	Usual
Interconnection	\$	49.6	\$	54.3	\$	7.3			110810111111	00000
Transmission - Constraint Relief	\$	48.4	\$	13.0	\$	7.9	Emissions (short tons)			
Transmission - Voltage Support	\$	0.5	\$	0.1	\$	0.2	SO2 (000)	93	873	1,122
Generation	\$	868.1	\$	679.4		242.3	N0x (000)	21	1,300	1,771
Nuclear Uprates	\$	4.9	\$	4.9	\$	4.9	` ,		,	, , ,
Pollution Retrofit Costs	\$	6.8	\$	20.2	\$	22.0	CO2 (000)	358	1,391	1,792
Distributed Generation	\$	-	\$	-	\$	-	Peak Demand (MW)	565,012	673,108	690,492
Total Capital Costs	\$	978.2	\$	771.9	\$	284.6	Energy (Twh)	2,979	3,621	3,687



EIPC 2013 Activities

Phase 2 Gas-Electric Interface Analyses

> EIPC Work Plan 2013-2014 (non-grant)



Phase 2 Gas-Electric Interface

- Proposed scope Analysis of the interface between natural gas and electric transmission infrastructures
- Principal Investigators from EIPC PJM as the project recipient, New England ISO, the Independent Electricity System Operator (IESO) Ontario, Canada, New York ISO, Midwest ISO, and TVA
- ➤ Timeline January, 2013 to December, 2014
- Technical analysis to be performed by a new contractor as a result of an RFP (spring, 2013)



- > Create/modify 2018 and 2023 steady-state load-flow models
 - Summer Peak (other seasons as needed)
- > Perform AC analysis for model validation
- Perform linear transfer analysis as specified in SMLFWG Procedure Manual
- Development of future transmission enhancements as required
- Compilation of analysis into a report



SMLFWG Case Development

- 2012 ERAG MMWG cases will be used as a starting point
- Planning Authorities will adjust loads, interchange, generation, etc. as necessary
- Regional Coordinators will assist with accurate data collection
- ➤ AC N-1 analysis will be performed for model validation



Linear Analysis

Will be performed to demonstrate strength of the grid, not to identify constraints such that transmission projects can be identified and transfer capability increased. Once linear analysis performed, individual Planning Authorities (PA) will share expansion plans with other PA on regional basis to look for enhancements.

Report

Once models are finalized, analyses are performed, enhancements are identified, and reporting data gathered, "Roll-Up" report will be assembled and sent out for review. Meeting will be held with stakeholders to review report (11/13)

http://www.eipconline.com/



SERC Long Term Study Group Update




SERC Long Term Study Group

Finishing report on 2016 MATS implementation impact study

2016 Summer Study Report available with FERC 715 filings

2013 model building process has begun







2016 LTSG STUDY RESULTS

SIGNIFICANT FACILITIES

Antioch 500/230 kV Transformers

The outage of either bank may limit Dominion-Duke and Gateway Subregion-VACAR transfers. The impedance difference between the banks causes the limit to be different for each bank. Duke Energy plans to upgrade these banks by 2014.

McGuire 500/230 kV Transformer

For the outage of the Woodleaf-Pleasant Garden 500 kV line, the McGuire 500/230 kV bank may limit Ameren-Duke transfers. The contingency's impact on the McGuire 500/230 kV transformer is directly related to the participation of McGuire Unit 1 in the transfer. Duke Energy has no plans for upgrades at this time, but will continue to monitor the facility.

SIGNIFICANT FACILITIES

McGuire – Riverbend Steam Station 230 kV 1/2

These lines may become overloaded during Progress East, LGEE, SCPSA, SGEG, SOCO and TVA to Duke transfers for outage of one of the parallel lines. Duke Energy plans to mitigate the issue through redispatching its generation at Lincoln CT Station.

Parkwood 500/230 kV Transformers

The outage of either parallel bank may limit Duke transfers to Ameren, Progress East, and Dominion; GTC and TVA transfers to Progress East; and GTC and TVA transfers to Dominion. An ancillary equipment upgrade can eliminate the lower transfer limits caused by limitations on bank 6. Future plans are to open the parallel bank for outage of either bank in order to mitigate the issue; however, Duke Energy continues to evaluate alternative future corrective actions.



SIGNIFICANT FACILITIES

Progress Energy identified no significant facilities resulting from this study.



NERC Reliability Standards Update



TPL "footnote b" remand – NERC BOT approved

TPL - 003/4 – Stuck breaker and/or PS failure
 NERC BOT approved

BES definition guidance document – FERC approved







2013 TAG Work Plan

Rich Wodyka ITP



2013 NCTPC Overview Schedule

Reliability Planning Process

- > Evaluate current reliability problems and transmission upgrade plans
 - > Perform analysis, identify problems, and develop solutions
 - ➤ Review Reliability Study Results

Enhanced Access Planning Process

- > Propose and select enhanced access scenarios and interface
 - > Perform analysis, identify problems, and develop solutions
 - ➤ Review Enhanced Access Study Results

Coordinated Plan Development

- Combine Reliability and Enhanced Results
 - ➤ OSC publishes DRAFT Plan
 - > TAG review and comment

TAG Meetings 1st Quarter 2nd Quarter 3rd Quarter 4th Quarter 131



2013 TAG Work Plan

January – February

- 2013 Study Finalize Study Scope of Work
 - ✓ Receive final 2013 Reliability Study Scope for comment
 - ✓ Review and provide comments to the OSC on the final 2013 Study Scope
 - ✓ Receive request from OSC to provide input on proposed Enhanced Transmission Access scenarios and interfaces for study
 - ✓ Provide input to the OSC on proposed Enhanced Transmission Access scenarios and interfaces for study



March 14th changed to April 16th TAG Meeting

- 2013 Study Update
 - ✓ Receive a progress report on the Reliability Planning study activities and preliminary results
- Order 1000 Update
 - ✓ Receive report on the direction that the NCTPC is heading on the Order 1000 regional compliance
 - Receive an update on the overall Compliance Timeline highlighting when continued stakeholder involvement in the process will occur



April - May - June

- > 2013 Study Technical Analysis, Problem Identification, and Solution Development
 - TAG will be requested to provide input to the OSC and PWG on the technical analysis performed, the problems identified as well as proposing alternative solutions to the problems identified
 - TAG will be requested to provide input to the OSC and PWG on any proposed alternative solutions to the problems identified through the technical analysis



April - May - June

TAG Meeting scheduled for June 10th

- > 2013 Study Update
 - Receive a progress report on the Reliability Planning study activities and preliminary results
 - Receive update status of the upgrades in the 2012 Collaborative Plan
- > Order 1000 Update
 - Receive an update on the Order 1000 regional compliance work and the discuss changes that will be coming in the regional compliance documents
 - Receive an update on the overall Compliance Timeline highlighting when continued stakeholder involvement in the process will occur



July - August - September

> 2013 Study Update

Receive a progress report on the Reliability Planning study activities and preliminary results

> 2013 Selection of Solutions

 TAG will receive feedback from the OSC on any alternative solutions that were proposed by TAG members



July - August - September TAG Meeting

> 2013 Study Update

Receive a progress report on the Reliability Planning study activities and preliminary results

> Order 1000 Update

- Receive an update on the Order 1000 regional compliance work and discuss the proposed changes that will be coming in the regional compliance documents
- Receive an update on the overall Compliance Timeline highlighting when continued stakeholder involvement in the process will occur



October - November - December

- > 2013 Study Update
 - Receive and comment on final draft of the 2013 Collaborative Transmission Plan report
 - Discuss potential study scope for 2014 studies



October - November - December TAG Meeting

- > 2013 Study Update
 - Receive presentation on the draft report of 2013
 Collaborative Transmission Plan
 - Discuss potential study scope for 2014 studies
- > Order 1000 Update
 - Receive an update on the Order 1000 regional compliance work







TAG Open Forum Discussion

Comments or Questions?